



__" DIA. ELECTRICAL HUBS ON 5" CENTERLINE (QTY __)

METER BY OTHERS



A

SS POLES W/CAPS OR CONCRETE MOUNTING POSTS AND SERVICE DISCONNECT WITH LIGHTNING ARRESTOR PER LOCAL CODE (BY CONTRACTOR)

SS BOLTS FOR ALUMINUM COVER

WARNING LIGHT

ALARM

CONTROL PANEL WITH LOCKING PROVISION

2" DIA. CONDUIT QTY. 3 FOR PUMP, POWER CABLES, SENSOR CABLES AND FLOATS (BY CONTRACTOR).

HOSE BIBB AND BFP (BY OTHERS) (INSTALL PER LOCAL CODES)

AUXILIARY POWER HOOKUP (OPTIONAL)

ALARM SILENCE BUTTON

__" DIA. VENT W/ SS BUG SCREEN

ALUMINUM ACCESS COVER WITH LOCKING HASP

SS HOOK CABLE HOLDER

PIPING CONNECTION DONE IN FIELD (BY CONTRACTOR)

GRADE

PER CODE

__" DIA. INLET GROMMET (SHIPPED LOOSE)

FIBERGLASS BASIN

__" DIA. UNION BALL VALVE

__" DIA. CHECK VALVE

__" DIA SCH. 80 PVC DISCHARGE PIPE

HIGH WATER ALARM

PUMP ON


PUMP OFF

SS LIFTING CABLE

SS LIFTING BAIL

B

PUMP SPECIFICATIONS	
PUMPS REQUIRED	1
MANUFACTURER	_____
MODEL NUMBER	_____
PUMP SIZE	_____
CAPACITY EACH (GPM)	_____
TOTAL HEAD (FEET)	_____
IMPELLER DIAMETER	_____
MOTOR HP REQUIRED	_____
SPEED (RPM)	_____
ELECTRICAL	_____
TANK DIMENSIONS	
"A" (DIA.)	"B" (HEIGHT)
<input type="checkbox"/> 24"	<input type="checkbox"/> 60"
<input type="checkbox"/> 36"	<input type="checkbox"/> 72"
<input type="checkbox"/> OTHER ____	<input type="checkbox"/> OTHER ____

REV.	REVISION DESCRIPTION	DATE	DRAWING NOT RELEASED UNTIL APPROVED & DATED		 BARNEY'S PUMPS, INC. PO BOX 3529, LAKELAND, FL 33802 PHONE: (863) 665-8500 FAX: (863) 666-3858
△	-	-	ENGINEER SIGNATURE/DATE:		
			ENGINEER:	-	CUSTOMER: BPI
			PHASE:	PRELIM	JOB NAME: SIMPLEX GRINDER PUMP NO RAIL SYSTEM
			SCALE:	1:25	JOB TITLE: SIMPLEX GRINDER FIBERGLASS NO RAILS INTERNAL VALVES
			DATE:	12/15/2025	SALESPERSON: -
			JOB No.:	SO: -	PRD: -
			DWG. No.:	WW-1GF100	PAGE: 1 OF 1
					REV. A